

Bacteriological Water Analysis Report

1

Water System Owner Rocky Harbour		Municipal Water Supply Reference Number (if applicable)
Address		
Postal Code		Telephone
Sample Collected by Amanda Baker		Date Sample(s) Collected Y Y Y Y M M D D 2024 11 20
GSC Location Corner Brook		

Water Supply Results

2

I.D.#	Sampling Sites	Time Collected	Total Coliforms (Present, Absent or #/100ml)	Fecal Coliforms (E.coli) (Present, Absent or #/100ml)	Chlorine Residual (mg/l)		Interpretation
					Free Cl ₂	Total Cl ₂	
1	Fisherman's landing	1:25	absent	absent	0.99	1.15	satisfactory
2	Oceanview	1:35	absent	absent	0.33	0.55	satisfactory
3	Coyley's	1:45	absent	absent	0.16	0.28	satisfactory
4	Irving	1:55	absent	absent	1.18	1.34	satisfactory

Remarks

3

Water is satisfactory and chlorine levels are good

Date Reported

Inspector's Name (Please Print)

Inspector's Signature


4

Y Y Y Y M M D D 2024/12/02

5

Penny Burke

6



For more information contact a Government Service Centre representative at one of the offices listed below:

7

Mount Pearl 729-3699	Harbour Grace 945-3106	Clarenville 466-4060	Marystown 270-0233	Gander 256-1420	Grand Falls-Windsor 292-4206
Lewisporte 535-0262	Springdale 673-4218	Corner Brook 637-2204	Stephenville 643-8650	St. Anthony 454-8833	Happy Valley-Goose Bay 896-5428

Run Date: 22/11/24
Run Time: 1430

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 10

** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0004198R **OLL:** 20/11/24-1325 **COLLECTED BY:** AB
RECD: 21/11/24-0900 **SOURCE:** WATER

COMMENTS: SAMPLING SITE:FISHERMANS LANDING

Procedure	Result	Verified	Site
*** MICROBIOLOGY ***			
> BACTERIOLOGICAL WATER ANALYSIS	Final	22/11/24-1201	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 22/11/24
Run Time: 1430

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 11
** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0004199R **OLL:** 20/11/24-1335 **COLLECTED BY:** AB
RECD: 21/11/24-0901 **SOURCE:** WATER

COMMENTS: SAMPLING SITE:OCEANVIEW

Procedure	Result	Verified	Site
*** MICROBIOLOGY ***			
> BACTERIOLOGICAL WATER ANALYSIS	Final	22/11/24-1201	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 22/11/24
Run Time: 1430

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 12

** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0004200R **OLL:** 20/11/24-1345 **COLLECTED BY:** AB
RECD: 21/11/24-0901 **SOURCE:** WATER

COMMENTS: SAMPLING SITE:COYLEY'S

Procedure	Result	Verified	Site
-----------	--------	----------	------

*** MICROBIOLOGY ***

> BACTERIOLOGICAL WATER ANALYSIS	Final	22/11/24-1202	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 22/11/24
Run Time: 1430

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 13
** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0004201R **OLL:** 20/11/24-1355 **COLLECTED BY:** AB
RECD: 21/11/24-0902 **SOURCE:** WATER

COMMENTS: SAMPLING SITE:IRVING

Procedure	Result	Verified	Site
-----------	--------	----------	------

*** MICROBIOLOGY ***

> BACTERIOLOGICAL WATER ANALYSIS	Final	22/11/24-1202	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		