

Bacteriological Water Analysis Report

1

Water System Owner <i>Rocky Harbour</i>		Municipal Water Supply Reference Number (if applicable)	
Address			
		Postal Code	Telephone
Sample Collected by <i>Ryan Osmond</i>		Date Sample(s) Collected Y Y Y Y M M D D <i>2024 10 23</i>	
GSC Location <i>Corner Brook</i>			

2

Water Supply Results

I.D. #	Sampling Sites	Time Collected	Total Coliforms (Present, Absent or #/100ml)	Fecal Coliforms (E.coli) (Present, Absent or #/100ml)	Chlorine Residual (mg/l)		Interpretation
					Free Cl ₂	Total Cl ₂	
1	<i>Irving</i>	<i>10:20</i>	<i>absent</i>	<i>absent</i>	<i>2.11</i>		<i>satisfactory</i>
2	<i>Coyle, 3</i>	<i>10:30</i>	<i>absent</i>	<i>absent</i>	<i>0.61</i>		<i>satisfactory</i>
3	<i>Fishermen's Landing</i>	<i>10:40</i>	<i>absent</i>	<i>absent</i>	<i>2.10</i>		<i>satisfactory</i>
4	<i>TW</i>	<i>10:00</i>	<i>absent</i>	<i>absent</i>	<i>1.72</i>		<i>satisfactory</i>

3

Remarks

All samples are satisfactory and chlorine levels are good

4

Date Reported

Y	Y	Y	Y	M	M	D	D
2024/11/06							

5

Inspector's Name (Please Print)

Penny Burke

6

Inspector's Signature

<i>P. Burke</i>

7

For more information contact a Government Service Centre representative at one of the offices listed below:

Mount Pearl 729-3699	Harbour Grace 945-3106	Clareville 466-4060	Marystown 279-0233	Gander 256-1420	Grand Falls-Windsor 292-4206
Lewisporte 535-0262	Springdale 673-4218	Corner Brook 637-2204	Stephenville 643-8650	St. Anthony 454-8833	Happy Valley-Goose Bay 896-5428

Run Date: 25/10/24

Western Health Care Corp. - LAB **LIVE**

Page: 9

Run Time: 1031

Corner Brook, NL
Department Of Laboratory

** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0003804R

OLL: 23/10/24-1020

COLLECTED BY: RO

RECD: 23/10/24-1355

SOURCE: WATER

COMMENTS: SAMPLING SITE:IRVING

Procedure

Result

Verified

Site

*** MICROBIOLOGY ***

> BACTERIOLOGICAL WATER ANALYSIS Final

24/10/24-1531

TOTAL COLIFORMS ABSENT / 100ML

FECAL COLIFORM (E. COLI) ABSENT / 100ML

Run Date: 25/10/24
Run Time: 1031

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 10

** LIVE **

NAME: MW, ROCKY HARBOUR**Report for:** GOV.SERV.CENTRE**SPEC #:** 24:WA0003805R**OLL:** 23/10/24-1030**COLLECTED BY:** RO**RECD:** 23/10/24-1356**SOURCE:** WATER**COMMENTS:** SAMPLING SITE:COLEYS**Procedure****Result****Verified****Site**

*** MICROBIOLOGY ***

> BACTERIOLOGICAL WATER ANALYSIS Final

24/10/24-1531

TOTAL COLIFORMS ABSENT / 100ML

FECAL COLIFORM (E. COLI) ABSENT / 100ML

Run Date: 25/10/24

Western Health Care Corp. - LAB **LIVE**

Page: 11

Run Time: 1031

Corner Brook, NL

Department Of Laboratory

** LIVE **

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 24:WA0003806R

OLL: 23/10/24-1040

COLLECTED BY: RO

RECD: 23/10/24-1356

SOURCE: WATER

COMMENTS: SAMPLING SITE:FISHERMANS LANDING

Procedure

Result

Verified

Site

*** MICROBIOLOGY ***

> BACTERIOLOGICAL WATER ANALYSIS Final

24/10/24-1531

TOTAL COLIFORMS ABSENT / 100ML

FECAL COLIFORM (E. COLI) ABSENT / 100ML

Run Date: 25/10/24
Run Time: 1031

Western Health Care Corp. - LAB **LIVE**
Corner Brook, NL
Department Of Laboratory

Page: 12

** LIVE **

NAME: MW, ROCKY HARBOUR**Report for:** GOV.SERV.CENTRE**SPEC #:** 24:WA0003807R**OLL:** 23/10/24-1100**COLLECTED BY:** R**RECD:** 23/10/24-1357**SOURCE:** WATER**COMMENTS:** SAMPLING SITE:TCO**Procedure****Result****Verified****Site******* MICROBIOLOGY *******> BACTERIOLOGICAL WATER ANALYSIS****Final**

24/10/24-1531

TOTAL COLIFORMS**ABSENT / 100ML****FECAL COLIFORM (E. COLI)****ABSENT / 100ML**