

# Bacteriological Water Analysis Report

**1** Water System Owner: Rocky Harbour Municipal Water Supply Reference Number (if applicable)

Address

Postal Code Telephone

Sample Collected by: Laden Brate Date Sample(s) Collected: 2025 01 15  
Y Y Y Y M M D D

GSC Location: Corner Brook

## Water Supply Results

**2**

I.D.#	Sampling Sites	Time Collected	Total Coliforms (Present, Absent or #/100ml)	Fecal Coliforms (E.coli) (Present, Absent or #/100ml)	Chlorine Residual (mg/l)		Interpretation
					Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	
1	Coxley's	12:50 pm	absent	absent	0.03	0.13	satisfactory
2	TCD	1:11 pm	absent	absent	0.33		satisfactory
3	Fisherman's Landing	1:26 pm	absent	absent	0.77		satisfactory
4	Irving	1:38 pm	absent	absent	1.02		satisfactory

## Remarks

**3**

All samples are satisfactory and chlorine levels are good

**4** Date Reported: 2025/01/23  
Y Y Y Y M M D D

**5** Inspector's Name (Please Print): Penny Burke

**6** Inspector's Signature: P. Burke

For more information contact a Government Service Centre representative at one of the offices listed below:

**7**

Mount Pearl 729-3699	Harbour Grace 945-3106	Clareville 466-4060	Marytown 279-0233	Gander 256-1420	Grand Falls-Windsor 292-4206
Lewisporte 535-0262	Springdale 673-4218	Corner Brook 637-2204	Stephenville 643-8650	St. Anthony 454-8833	Happy Valley-Goose Bay 896-5428

Run Date: 17/01/25  
Run Time: 1430

Western Health Care Corp. - LAB \*\*LIVE\*\*  
Corner Brook, NL  
Department Of Laboratory

Page: 19  
\*\* LIVE \*\*

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 25:WA0000165R      OLL: 15/01/25-1250      COLLECTED BY: CB  
RECD: 16/01/25-1215      SOURCE: WATER

COMMENTS: SAMPLING SITE:COYLEYS

Procedure	Result	Verified	Site
-----------	--------	----------	------

\*\*\* MICROBIOLOGY \*\*\*

> BACTERIOLOGICAL WATER ANALYSIS	Final	17/01/25-1322	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 17/01/25  
Run Time: 1430

Western Health Care Corp. - LAB \*\*LIVE\*\*  
Corner Brook, NL  
Department Of Laboratory

Page: 20  
\*\* LIVE \*\*

NAME: MW, ROCKY HARBOUR			
Report for: GOV.SERV.CENTRE			
SPEC #:	25:WA0000166R	OLL: 15/01/25-1310	COLLECTED BY: CB
		RECD: 16/01/25-1215	SOURCE: WATER
COMMENTS: SAMPLING SITE:TCO			
Procedure	Result	Verified	Site
*** MICROBIOLOGY ***			
> BACTERIOLOGICAL WATER ANALYSIS	Final		17/01/25-1322
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 17/01/25  
Run Time: 1430

Western Health Care Corp. - LAB \*\*LIVE\*\*  
Corner Brook, NL  
Department Of Laboratory

Page: 21

\*\* LIVE \*\*

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 25:WA0000167R      OLL: 15/01/25-1326      COLLECTED BY: CB  
RECD: 16/01/25-1216      SOURCE: WATER

COMMENTS: SAMPLING SITE:FISHERMANS LANDING

Procedure	Result	Verified	Site
-----------	--------	----------	------

\*\*\* MICROBIOLOGY \*\*\*

> BACTERIOLOGICAL WATER ANALYSIS	Final	17/01/25-1322	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		

Run Date: 17/01/25  
Run Time: 1430

Western Health Care Corp. - LAB \*\*LIVE\*\*  
Corner Brook, NL  
Department Of Laboratory

Page: 22

\*\* LIVE \*\*

NAME: MW, ROCKY HARBOUR

Report for: GOV.SERV.CENTRE

SPEC #: 25:WA0000168R      OLL: 15/01/25-1338      COLLECTED BY: CB  
RECD: 16/01/25-1338      SOURCE: WATER

COMMENTS: SAMPLING SITE:IRVING

Procedure	Result	Verified	Site
*** MICROBIOLOGY ***			
> BACTERIOLOGICAL WATER ANALYSIS	Final	17/01/25-1322	
TOTAL COLIFORMS	ABSENT / 100ML		
FECAL COLIFORM (E. COLI)	ABSENT / 100ML		